

## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 019

 Customer
 Sample Collection

 Facility Name:
 Baxter Building
 Date: 12/3/24

 Time:
 8:33 AM

 Address:
 925 Brushton Ave
 Method: Grab

Pittsburgh, PA 15208

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM

Source Type: Pool Shallow Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation D	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	Α	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	Α	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	Α	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	Α	12/3/24	8:33 AM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	В	12/3/24	8:33 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	Α	12/3/24	8:33 AM	SCL	Visual

## Sample comments

andre Smith



## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 019

 Customer
 Sample Collection

 Facility Name:
 Baxter Building
 Date: 12/3/24

 Time:
 8:33 AM

 Address:
 925 Brushton Ave
 Method: Grab

Pittsburgh, PA 15208

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM

Source Type: Pool Shallow Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation D	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	Α	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	Α	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	Α	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	Α	12/3/24	8:33 AM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	В	12/3/24	8:33 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	Α	12/3/24	8:33 AM	SCL	Visual

## Sample comments

andre Smith