



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 313

**Customer**

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/10/24

Time: 10:30 AM

Method: Grab

**Sample Final Analysis**

Date: 12/13/24

Time: 9:00 AM

Analyst: AS

| Laboratory Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 12/11/24             | 10:50 AM | PS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 12/11/24             | 10:50 AM | PS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 12/10/24             | 4:15 PM  | AS      | SM 9215B |

| Additional Analysis | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|---------------------|----------|-----------------|----------------------|----------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls        | 12/11/24             | 11:25 AM | PS      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.5 SU   | 7.2 - 7.8 SU    | 12/10/24  | 10:30 AM | JR      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 12/10/24  | 10:30 AM | JR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 12/10/24  | 10:30 AM | JR      | Visual |

**Sample comments**

*Anne Smith*

( When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 313

**Customer**

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive  
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 12/10/24

Time: 10:30 AM

Method: Grab

**Sample Final Analysis**

Date: 12/13/24

Time: 9:00 AM

Analyst: AS

| Laboratory Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 12/11/24             | 10:50 AM | PS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 12/11/24             | 10:50 AM | PS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 12/10/24             | 4:15 PM  | AS      | SM 9215B |

| Additional Analysis | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|---------------------|----------|-----------------|----------------------|----------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls        | 12/11/24             | 11:25 AM | PS      | SM 9230C |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.5 SU   | 7.2 - 7.8 SU    | 12/10/24  | 10:30 AM | JR      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 12/10/24  | 10:30 AM | JR      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 12/10/24  | 10:30 AM | JR      | Visual |

**Sample comments**

*Andrea Smith*

( When exceeding reporting limit pool or spa is unfit)