1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab#   443

Customer | | **Sample Collection**
Facility Name: | Highpoint Fitness | *Date:* 12/4/24
 | | *Time:* 1:17 PM
Address: | 1000 Higbee Dr. | *Method:* Grab
 | Bethel Park, PA 15102 |
 | | **Sample Final Analysis**
Matrix: | Recreational Water | *Date:* 12/7/24
 | | *Time:* 9:00 AM
Source Type: | Pool | *Analyst:* AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/4/24	1:17 PM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	1:17 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	1:17 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 443

Customer

Facility Name:	*Highpoint Fitness*	
Address:	*1000 Higbee Dr.*	
	Bethel Park, PA 15102	
Matrix:	*Recreational Water*	
Source Type:	*Pool*	

Sample Collection

Date:	*12/4/24*
Time:	1:17 PM
Method:	*Grab*

Sample Final Analysis

Date:	*12/7/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/4/24	1:17 PM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	1:17 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	1:17 PM	SCL	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith