1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 409

Customer		**Sample Collection**
Facility Name:	*Best Western Cranberry*	*Date:* 12/2/24
		Time: 8:12 AM
Address:	*5001 Cranberry Springs Dr.*	*Method:* Grab
	Cranberry, PA 16066	
		Sample Final Analysis
Matrix:	*Recreational Water*	*Date:* 12/5/24
		Time: 9:00 AM
Source Type:	*Pool*	*Analyst:* AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	8:12 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	8:12 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	8:12 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# 409

Customer

Facility Name:	*Best Western Cranberry*		
Address:	*5001 Cranberry Springs Dr.* *Cranberry, PA 16066*		
Matrix:	*Recreational Water*		
Source Type:	*Pool*		

Sample Collection

Date:	*12/2/24*
Time:	*8:12 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*12/5/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24	8:12 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	8:12 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	8:12 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)