

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

S-3

Lab ID No. 02-04041

Lab# 160

Sample Collection Customer Facility Name: Holiday Inn Express Date: 12/2/24 2:00 PM Time: Address: 810 Highland Meadow Dr. Method: Grab Washington, PA 15301 Sample Final Analysis Recreational Water Date: 12/5/24 Matrix: Time: 9:00 AM Source Type: Analyst: AS Spa Reporting limit **Laboratory Analysis** Results Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 12/3/24 9:30 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 12/3/24 9:30 AM AS SM 9222B Standard plate count: 0/ml 200/ml 12/2/24 5:15 PM AS SM 9215B **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Fecal Streptococcus 0/100mls 2/100mls 12/3/24 Total coliforms: AS SM 9230C **Field Analysis** Results Reporting limit Date/Time **Analyst** Method pH: 7.6 SU 7.2 - 7.8 SU 12/2/24 2:00 PM JM DPD 1.0 - 5.0 mg/l Chlorine: 2.0 mg/l 12/2/24 2:00 PM JM DPD

12/2/24

Sample comments

Turbidity:

andre Smith

2:00 PM

JM

Visual

1 NTU

1 - 2 NTU



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

S-3

Lab ID No. 02-04041

Lab# 160

Sample Collection Customer Facility Name: Holiday Inn Express Date: 12/2/24 2:00 PM Time: Address: 810 Highland Meadow Dr. Method: Grab Washington, PA 15301 Sample Final Analysis Recreational Water Date: 12/5/24 Matrix: Time: 9:00 AM Source Type: Analyst: AS Spa Reporting limit **Laboratory Analysis** Results Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 12/3/24 9:30 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 12/3/24 9:30 AM AS SM 9222B Standard plate count: 0/ml 200/ml 12/2/24 5:15 PM AS SM 9215B **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Fecal Streptococcus 0/100mls 2/100mls 12/3/24 Total coliforms: AS SM 9230C **Field Analysis** Results Reporting limit Date/Time **Analyst** Method pH: 7.6 SU 7.2 - 7.8 SU 12/2/24 2:00 PM JM DPD 1.0 - 5.0 mg/l Chlorine: 2.0 mg/l 12/2/24 2:00 PM JM DPD

12/2/24

Sample comments

Turbidity:

andre Smith

2:00 PM

JM

Visual

1 NTU

1 - 2 NTU