



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 312

Customer

Facility Name: UPMC Lemieux Sports Complex

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge

Sample Collection

Date: 12/17/24

Time: 1:30 PM

Method: Grab

Sample Final Analysis

Date: 12/20/24

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/18/24	10:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/18/24	10:30 AM	PS	SM 9222B
Standard plate count:	120/ml	200/ml	12/17/24	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.7 SU	7.2 - 7.8 SU	12/17/24	1:30 PM	JR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	12/17/24	1:30 PM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/17/24	1:30 PM	JR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 312

Customer

Facility Name: UPMC Lemieux Sports Complex

Address: 8000 Cranberry Springs Drive
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge

Sample Collection

Date: 12/17/24

Time: 1:30 PM

Method: Grab

Sample Final Analysis

Date: 12/20/24

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/18/24	10:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/18/24	10:30 AM	PS	SM 9222B
Standard plate count:	120/ml	200/ml	12/17/24	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.7 SU	7.2 - 7.8 SU	12/17/24	1:30 PM	JR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	12/17/24	1:30 PM	JR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/17/24	1:30 PM	JR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith