



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

Service

Lab# 121

Laboratory Analysis Report

Customer

Facility Name: Hampton Inn
Address: 301 West Waterfront Dr.
Pittsburgh, PA 15120

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/2/24
Time: 1:45 PM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	12/2/24	1:45 PM	DS	DPD
Chlorine:	1.6 mg/l	1.0 - 5.0 mg/l	12/2/24	1:45 PM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	1:45 PM	DS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith