



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 215

Customer

Facility Name: Longwood at Oakmont

Address: 500 Rt. 909
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/5/23

Time: 11:35 AM

Method: Grab

Sample Final Analysis

Date: 12/8/23

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	9:55 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	9:55 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	11:35 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/5/23	11:35 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	11:35 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 215

Customer

Facility Name: Longwood at Oakmont

Address: 500 Rt. 909
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/5/23

Time: 11:35 AM

Method: Grab

Sample Final Analysis

Date: 12/8/23

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	9:55 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	9:55 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	11:35 AM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/5/23	11:35 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	11:35 AM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)