

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 379

<u>Customer</u> <u>Sample Collection</u>

Facility Name: PPG Paints Arena Date: 12/9/24
Time: 12:15 PM

Address: 1001 Fifth Ave Method: Grab

Pittsburgh, PA 15219

Matrix: Recreational Water Sample Final Analysis

Date: 12/12/24

Source Type: Spa Time: 9:00 AM
Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent 9:10 AM PS SM 9222G Absent 9/10/24 Total coliforms: 0/100mls 2/100mls 9/10/24 PS 9:10 AM SM 9222B Standard plate count: 0/ml 200/ml 12/9/24 5:00 PM AS SM 9215B **Additional Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method PS Fecal Streptococcus 0/100mls 2/100mls 9/10/24 9:55 AM SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	12/9/24	12:15 PM	DS	DPD
Chlorine:	2.8 mg/l	1.0 - 5.0 mg/l	12/9/24	12:15 PM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/24	12:15 PM	DS	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 379

<u>Customer</u> <u>Sample Collection</u>

Facility Name: PPG Paints Arena Date: 12/9/24
Time: 12:15 PM

Address: 1001 Fifth Ave Method: Grab

Pittsburgh, PA 15219

Matrix: Recreational Water Sample Final Analysis

Date: 12/12/24

Source Type: Spa Time: 9:00 AM
Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent 9:10 AM PS SM 9222G Absent 9/10/24 Total coliforms: 0/100mls 2/100mls 9/10/24 PS 9:10 AM SM 9222B Standard plate count: 0/ml 200/ml 12/9/24 5:00 PM AS SM 9215B **Additional Analysis** Results Reporting limit **Incubation Date/Time Analyst** Method PS Fecal Streptococcus 0/100mls 2/100mls 9/10/24 9:55 AM SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	12/9/24	12:15 PM	DS	DPD
Chlorine:	2.8 mg/l	1.0 - 5.0 mg/l	12/9/24	12:15 PM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/24	12:15 PM	DS	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)