



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 451

Customer

Facility Name: Kiski Area H.S.
Address: 240 Hyde Park Rd.
Leechburg, PA 15656

Sample Collection

Date: 12/3/24
Time: 1:31 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM
Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/4/24 | 10:15 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/4/24 | 10:15 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/3/24 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 12/3/24 | 1:31 PM | AH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 12/3/24 | 1:31 PM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/3/24 | 1:31 PM | AH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 451

Customer

Facility Name: Kiski Area H.S.
Address: 240 Hyde Park Rd.
Leechburg, PA 15656

Sample Collection

Date: 12/3/24
Time: 1:31 PM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM
Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/4/24 10:15 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/4/24 10:15 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/3/24 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 12/3/24 1:31 PM | AH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 12/3/24 1:31 PM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/3/24 1:31 PM | AH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)