1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

		Sample Collection	
Facility Name:	Hampton Inn & Suites	Date:	12/3/24
		Time:	2:25 PM
Address:	200 Technology Dr.	Method:	Grab
	Coal Center, PA 15423		
		Sample Final Analysis	
Matrix:	Recreational Water	Date:	12/6/24
		Time:	9:00 AM
Source Type:	Pool	Analyst:	AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/3/24	2:25 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/3/24	2:25 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	2:25 PM	SH	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 127

Customer
Facility Name: Hampton Inn & Suites

Address: 200 Technology Dr.
Coal Center, PA 15423

Matrix: Recreational Water

Source Type: Pool

Sample Collection
Date: 12/3/24
Time: 2:25 PM
Method: Grab

Sample Final Analysis
Date: 12/6/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/3/24	2:25 PM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/3/24	2:25 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	2:25 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith