

## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**S-3** 

Lab# 151

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Hilton Garden Inn Date: 12/2/24
Time: 9:00 AM

Address: 1000 Corporate Dr. Method: Grab

Cannonsburg, PA 15317

Matrix: Recreational Water Date: 12/5/24

Source Type: Pool

Sample Final Analysis

Date: 12/5/24

Time: 9:00 AM

Analyst: AS

**Laboratory Analysis** Results Reporting limit **Incubation Date/Time** Analyst Method Escherichia Coli: Absent Absent 12/3/24 9:30 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 12/3/24 9:30 AM AS SM 9222B Standard plate count: 0/ml 200/ml 12/2/24 5:15 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/2/24	9:00 AM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:00 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:00 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

anobie Smith



## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**S-3** 

Lab# 151

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Hilton Garden Inn Date: 12/2/24
Time: 9:00 AM

Address: 1000 Corporate Dr. Method: Grab

Cannonsburg, PA 15317

Matrix: Recreational Water Date: 12/5/24

Source Type: Pool

Sample Final Analysis

Date: 12/5/24

Time: 9:00 AM

Analyst: AS

**Laboratory Analysis** Results Reporting limit **Incubation Date/Time** Analyst Method Escherichia Coli: Absent Absent 12/3/24 9:30 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 12/3/24 9:30 AM AS SM 9222B Standard plate count: 0/ml 200/ml 12/2/24 5:15 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/2/24	9:00 AM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:00 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:00 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

anobie Smith