1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 073

Customer	**_Sample Collection_**
Facility Name: Courtyard by Marriott	*Date:* 12/3/24
	Time: 8:05 AM
Address: 401 West Waterfront Dr.	*Method:* Grab
West Homestead, PA 15120	
	Sample Final Analysis
Matrix: Recreational Water	*Date:* 12/6/24
	Time: 9:00 AM
Source Type: Pool	*Analyst:* AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	570/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/3/24	8:05 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/3/24	8:05 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	8:05 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 073

B & R Pools and Swim Shop

Customer

Facility Name:	*Courtyard by Marriott*
Address:	*401 West Waterfront Dr.*
	West Homestead, PA 15120
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*12/3/24*
Time:	8:05 AM
Method:	*Grab*

Sample Final Analysis

Date:	*12/6/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	570/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/3/24	8:05 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/3/24	8:05 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	8:05 AM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)