



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 026

Customer

Facility Name: Brashear High School

Address: 590 Crane Ave
Pittsburgh, PA 15216

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 12/4/24

Time: 9:08 AM

Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 3:30 PM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/4/24	9:08 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	A	12/4/24	9:08 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/4/24	9:08 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 026

Customer

Facility Name: Brashear High School

Address: 590 Crane Ave
Pittsburgh, PA 15216

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 12/4/24

Time: 9:08 AM

Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 3:30 PM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/4/24	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/4/24	9:08 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	A	12/4/24	9:08 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/4/24	9:08 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)