1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

Facility Name:	Hilton Garden Inn	
Address:	2000 Garden View	
	Cranberry, PA 16066	
Matrix:	Recreational Water	
Source Type:	Pool	

Sample Collection

Date:	12/2/24
Time:	9:09 AM
Method:	Grab

Sample Final Analysis

Date:	12/5/24
Time:	9:00 AM
Analyst:	AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/2/24	9:09 AM	SCL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:09 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:09 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 153

Customer

Facility Name:	*Hilton Garden Inn*
Address:	*2000 Garden View*
	Cranberry, PA 16066
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*12/2/24*
Time:	9:09 AM
Method:	*Grab*

Sample Final Analysis

Date:	*12/5/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/2/24	9:09 AM	SCL	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:09 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:09 AM	SCL	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)