

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

P.P.S.

Lab# 003

Customer Facility Name:

Allderdice H.S.

Address:

2409 Shady Ave.

Pittsburgh, PA 15217

Matrix:

Recreational Water

Source Type:

Pool Deep

Sample Collection

Date:

12/3/24 10:10 AM

Time: Method:

Grab

Sample Final Analysis

Date:

12/6/24

Time: Analyst: 9:00 AM AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation D	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	Α	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	Α	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	Α	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
рН:	7.8 SU	7.2 - 7.8 SU	С	12/3/24	10:10 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	Α	12/3/24	10:10 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	Α	12/3/24	10:10 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

anobre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

P.P.S.

Lab# 003

Customer Facility Name:

Allderdice H.S.

Address:

2409 Shady Ave.

Pittsburgh, PA 15217

Matrix:

Recreational Water

Source Type:

Pool Deep

Sample Collection

Date:

12/3/24 10:10 AM

Time: Method:

Grab

Sample Final Analysis

Date:

12/6/24

Time: Analyst: 9:00 AM AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation D	ate/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	Α	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	Α	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	Α	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
рН:	7.8 SU	7.2 - 7.8 SU	С	12/3/24	10:10 AM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	Α	12/3/24	10:10 AM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	Α	12/3/24	10:10 AM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

anobre Smith