1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# ***381***

Customer		***Sample Collection***	
Facility Name:	*PPG Paints Arena*	*Date:*	*12/9/24*
		Time:	12:15 PM
Address:	*1001 Fifth Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15219		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/12/24*
		Time:	*9:00 AM*
Source Type:	*Cold Plunge*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/24	9:10 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/24	9:10 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/9/24	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/9/24	12:15 PM	DS	DPD
Chlorine:	2.2 mg/l	1.0 - 5.0 mg/l	12/9/24	12:15 PM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/24	12:15 PM	DS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# ***381***

Customer		***Sample Collection***	
Facility Name:	*PPG Paints Arena*	*Date:*	*12/9/24*
		Time:	12:15 PM
Address:	*1001 Fifth Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15219		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/12/24*
		Time:	*9:00 AM*
Source Type:	*Cold Plunge*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/10/24	9:10 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/24	9:10 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/9/24	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/9/24	12:15 PM	DS	DPD
Chlorine:	2.2 mg/l	1.0 - 5.0 mg/l	12/9/24	12:15 PM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/9/24	12:15 PM	DS	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andrea Smith