



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 225

Customer

Facility Name: Metropolitan
Address: 537 N Neville St
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/3/24
Time: 12:36 PM
Method: Grab

Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/3/24	12:36 PM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:36 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:36 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 225

Customer

Facility Name: Metropolitan
Address: 537 N Neville St
Pittsburgh, PA 15213

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 12/3/24
Time: 12:36 PM
Method: Grab

Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	11:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	11:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/3/24	12:36 PM	SCL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:36 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:36 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)