



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 436

**Customer**

Facility Name: Grove City College  
Address: 100 Campus Dr.  
Grove City, PA 16127

Matrix: Recreational Water

Source Type: Comp Pool

**Sample Collection**

Date: 12/5/23  
Time: 12:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	12:30 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/5/23	12:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	12:30 PM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 436

**Customer**

Facility Name: Grove City College  
Address: 100 Campus Dr.  
Grove City, PA 16127

Matrix: Recreational Water

Source Type: Comp Pool

**Sample Collection**

Date: 12/5/23  
Time: 12:30 PM  
Method: Grab

**Sample Final Analysis**

Date: 12/8/23  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	12:30 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/5/23	12:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	12:30 PM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*