

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

6.3

Lab ID No. 02-04041

S-2

Lab# 301

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Uniontown High School Date: 12/3/24

Address: 146 East Fayette Street Time: 1:45 PM

Method: Grab

Uniontown, PA 15401

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24

Source Type: Pool Time: 9:00 AM
Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 12/4/24 11:00 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 11:00 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 5:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	12/3/24	1:45 PM	SH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/3/24	1:45 PM	SH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	1:45 PM	SH	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

6.3

Lab ID No. 02-04041

S-2

Lab# 301

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Uniontown High School Date: 12/3/24

Address: 146 East Fayette Street Time: 1:45 PM

Method: Grab

Uniontown, PA 15401

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24

Source Type: Pool Time: 9:00 AM
Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 12/4/24 11:00 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 11:00 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 5:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	12/3/24	1:45 PM	SH	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/3/24	1:45 PM	SH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	1:45 PM	SH	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith