1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# **234**

Customer

Facility Name:	*North Allegheny High School*
Address:	*10375 Perry Hwy.*
	Wexford, PA 15090
Matrix:	*Recreational Water*
Source Type:	*Pool Deep*

Sample Collection

Date:	*12/6/23*
Time:	9:45 AM
Method:	*Grab*

Sample Final Analysis

Date:	*12/8/23*
Time:	*1:00 PM*
Analyst:	PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	9:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:45 AM	VH	Visual

Sample comments

_____

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer
Facility Name:	*North Allegheny High School*
Address:	*10375 Perry Hwy.*
	Wexford, PA 15090
Matrix:	*Recreational Water*
Source Type:	*Pool Deep*

Sample Collection
Date:	*12/6/23*
Time:	9:45 AM
Method:	*Grab*

Sample Final Analysis
Date:	*12/8/23*
Time:	*1:00 PM*
Analyst:	PS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/6/23	9:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/6/23	9:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	9:45 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)