

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-1

Lab ID No. 02-04041

Lab# 445

Customer Sample Collection

Facility Name: Highpoint Fitness Date: 12/4/24

1:17 PM Time: 1000 Higbee Dr. Method: Address: Grab

Bethel Park, PA 15102

Sample Final Analysis Matrix: Recreational Water Date: 12/7/24

Time: 9:00 AM Source Type: AS Spa Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12:00 AM	9:50 AM	AS	SM 9213C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/4/24	1:17 PM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/4/24	1:17 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	1:17 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-1

Lab ID No. 02-04041

Lab# 445

Customer Sample Collection

Facility Name: Highpoint Fitness Date: 12/4/24

1:17 PM Time: 1000 Higbee Dr. Method: Address: Grab

Bethel Park, PA 15102

Sample Final Analysis Matrix: Recreational Water Date: 12/7/24

Time: 9:00 AM Source Type: AS Spa Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12:00 AM	9:50 AM	AS	SM 9213C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/4/24	1:17 PM	SCL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/4/24	1:17 PM	SCL	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	1:17 PM	SCL	Visual

Sample comments

Andre Smith, Lead Supervisor

andre Smith

(When exceeding reporting limit pool or spa is unfit)