



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 211

Customer

Facility Name: L.A. Fitness North Hills

Address: 8700 Duncan Ave.
Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/4/24

Time: 8:15 AM

Method: Grab

Sample Final Analysis

Date: 12/7/24

Time: 9:00 AM

Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-------------------|--------|--------|-----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 12/5/24 9:50 AM | AS | SM 9222G |
|-------------------|--------|--------|-----------------|----|----------|

| | | | | | |
|------------------|----------|----------|-----------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 12/5/24 9:50 AM | AS | SM 9222B |
|------------------|----------|----------|-----------------|----|----------|

| | | | | | |
|-----------------------|------|--------|-----------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 12/4/24 4:15 PM | AS | SM 9215B |
|-----------------------|------|--------|-----------------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/5/24 9:50 AM | AS | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|-----|--------|--------------|-----------------|----|-----|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 12/4/24 8:15 AM | VH | DPD |
|-----|--------|--------------|-----------------|----|-----|

| | | | | | |
|-----------|----------|----------------|-----------------|----|-----|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/4/24 8:15 AM | VH | DPD |
|-----------|----------|----------------|-----------------|----|-----|

| | | | | | |
|------------|-------|-----------|-----------------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/4/24 8:15 AM | VH | Visual |
|------------|-------|-----------|-----------------|----|--------|

Sample comments

Anaë Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 211

Customer

Facility Name: L.A. Fitness North Hills

Address: 8700 Duncan Ave.
Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/4/24

Time: 8:15 AM

Method: Grab

Sample Final Analysis

Date: 12/7/24

Time: 9:00 AM

Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-------------------|--------|--------|-----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 12/5/24 9:50 AM | AS | SM 9222G |
|-------------------|--------|--------|-----------------|----|----------|

| | | | | | |
|------------------|----------|----------|-----------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 12/5/24 9:50 AM | AS | SM 9222B |
|------------------|----------|----------|-----------------|----|----------|

| | | | | | |
|-----------------------|------|--------|-----------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 12/4/24 4:15 PM | AS | SM 9215B |
|-----------------------|------|--------|-----------------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/5/24 9:50 AM | AS | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|-----|--------|--------------|-----------------|----|-----|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 12/4/24 8:15 AM | VH | DPD |
|-----|--------|--------------|-----------------|----|-----|

| | | | | | |
|-----------|----------|----------------|-----------------|----|-----|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/4/24 8:15 AM | VH | DPD |
|-----------|----------|----------------|-----------------|----|-----|

| | | | | | |
|------------|-------|-----------|-----------------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/4/24 8:15 AM | VH | Visual |
|------------|-------|-----------|-----------------|----|--------|

Sample comments

Anaë Smith

(When exceeding reporting limit pool or spa is unfit)