



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 223

Customer

Facility Name: McKeesport High School

Address: 1960 Eden Park Blvd.
McKeesport, PA 15132

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 12/3/24

Time: 2:05 PM

Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24 9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24 9:30 AM	PS	SM 9222B
Standard plate count:	70/ml	200/ml	12/3/24 3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/3/24 2:05 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24 2:05 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24 2:05 PM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 223

Customer

Facility Name: McKeesport High School

Address: 1960 Eden Park Blvd.
McKeesport, PA 15132

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 12/3/24

Time: 2:05 PM

Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24 9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24 9:30 AM	PS	SM 9222B
Standard plate count:	70/ml	200/ml	12/3/24 3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	12/3/24 2:05 PM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24 2:05 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24 2:05 PM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith