

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-2

Lab ID No. 02-04041

Lab# 141

Sample Collection **Customer**

Facility Name: Heinz House Date: 12/3/24 Time: 12:50 PM

Address: 1 Heinz St. Method: Grab

Pittsburgh, PA 15212

Sample Final Analysis Matrix: Recreational Water Date: 12/6/24 Time: 9:00 AM

Source Type: Pool Shallow Analyst: AS

Laboratory Analysis		Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:		Absent	12/4/24	9:30 AM	PS	SM 9222G	
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B	
Standard plate count:	0/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	12/3/24	12:50 PM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:50 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:50 PM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

C-2

Lab ID No. 02-04041

Lab# 141

Sample Collection **Customer**

Facility Name: Heinz House Date: 12/3/24 Time: 12:50 PM

Address: 1 Heinz St. Method: Grab

Pittsburgh, PA 15212

Sample Final Analysis Matrix: Recreational Water Date: 12/6/24 Time: 9:00 AM

Source Type: Pool Shallow Analyst: AS

Laboratory Analysis		Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:		Absent	12/4/24	9:30 AM	PS	SM 9222G	
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B	
Standard plate count:	0/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	12/3/24	12:50 PM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:50 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:50 PM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith