

Facility Name:

Address:

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E-2

Lab ID No. 02-04041

Lab# 128

Sample Collection **Customer**

Hampton Inn & Suites North Huntington Irwin Date: 12/3/24

Time: 9:15 AM 8441 Country Club Drive Method: Grab

North Huntingdon, PA 15642

Sample Final Analysis Matrix: Recreational Water Date: 12/6/24

9:00 AM Time: Source Type: Pool Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 12/4/24 9:30 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 9:30 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	12/3/24	9:15 AM	JC	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/3/24	9:15 AM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	9:15 AM	JC	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

anobie Smith



Facility Name:

Address:

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

E-2

Lab ID No. 02-04041

Lab# 128

Sample Collection **Customer**

Hampton Inn & Suites North Huntington Irwin Date: 12/3/24

Time: 9:15 AM 8441 Country Club Drive Method: Grab

North Huntingdon, PA 15642

Sample Final Analysis Matrix: Recreational Water Date: 12/6/24

9:00 AM Time: Source Type: Pool Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 12/4/24 9:30 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 9:30 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	12/3/24	9:15 AM	JC	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/3/24	9:15 AM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	9:15 AM	JC	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

anobie Smith