

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 090

Customer Sample Collection

Facility Name: Doubletree Hotel Date: 12/3/24

Address: Bigelow Square Time: 10:05 AM Method: Grab

Pittsburgh, PA 15219

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24

Source Type: Pool Time: 9:00 AM Analyst: AS

Laboratory Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 12/4/24 9:30 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 9:30 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	12/3/24	10:05 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24	10:05 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	10:05 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 090

Customer Sample Collection

Facility Name: Doubletree Hotel Date: 12/3/24

Address: Bigelow Square Time: 10:05 AM Method: Grab

Pittsburgh, PA 15219

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24

Source Type: Pool Time: 9:00 AM Analyst: AS

Laboratory Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: Absent Absent 12/4/24 9:30 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 9:30 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.4 SU	7.2 - 7.8 SU	12/3/24	10:05 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24	10:05 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	10:05 AM	JM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith