

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

E-2

Lab ID No. 02-04041

Lab# 202

<u>Customer</u> <u>Sample Collection</u>

Facility Name: L.A. Fitness Greensburg Date: 12/3/24

Address: Time: 12:52 PM

Method: Grab

Greensburg, PA 15601

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24

Source Type: Pool Time: 9:00 AM
Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method Incubation Date/Time Escherichia Coli: Absent Absent 12/4/24 9:30 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 9:30 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	12/3/24	12:52 PM	JC	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:52 PM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:52 PM	JC	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

E-2

Lab ID No. 02-04041

Lab# 202

<u>Customer</u> <u>Sample Collection</u>

Facility Name: L.A. Fitness Greensburg Date: 12/3/24

Address: Time: 12:52 PM

Method: Grab

Greensburg, PA 15601

Matrix: Recreational Water Sample Final Analysis

Date: 12/6/24

Source Type: Pool Time: 9:00 AM
Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method Incubation Date/Time Escherichia Coli: Absent Absent 12/4/24 9:30 AM PS SM 9222G Total coliforms: 0/100mls 2/100mls 12/4/24 9:30 AM PS SM 9222B Standard plate count: 0/ml 200/ml 12/3/24 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	12/3/24	12:52 PM	JC	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:52 PM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:52 PM	JC	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith