

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 375

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Southside Works Date: 12/3/24

Time: 2:40 PM
Address: 2626 South Tunnel Blvd Method: Grab

Pittsburgh, PA 15203

Matrix: Recreational Water Sample Final Analysis
Date: 12/6/24
Time: 9:00 AM

Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/3/24	2:40 PM	JM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/3/24	2:40 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	2:40 PM	JM	Visual

Sample comments

anobie Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

C-2

Lab# 375

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Southside Works Date: 12/3/24

Time: 2:40 PM
Address: 2626 South Tunnel Blvd Method: Grab

Pittsburgh, PA 15203

Matrix: Recreational Water Sample Final Analysis
Date: 12/6/24
Time: 9:00 AM

Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/3/24	2:40 PM	JM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/3/24	2:40 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	2:40 PM	JM	Visual

Sample comments

anobie Smith

(When exceeding reporting limit pool or spa is unfit)