1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 470

Customer

Facility Name:	*Hampton Inn*
Address:	*62 Pine Ridge Rd.*
	Blairsville, PA 15717
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*12/4/24*
Time:	11:02 AM
Method:	*Grab*

Sample Final Analysis

Date:	*12/7/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/4/24	11:02 AM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/4/24	11:02 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	11:02 AM	JC	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

E-3

Lab# 470

Customer		_Sample Collection_	
Facility Name:	*Hampton Inn*	*Date:*	*12/4/24*
		Time:	11:02 AM
Address:	*62 Pine Ridge Rd.*	*Method:*	*Grab*
	Blairsville, PA 15717		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/7/24*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/4/24	11:02 AM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/4/24	11:02 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	11:02 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)