

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 313

<u>Customer</u>

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive

Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/3/24

Time: 9:15 AM Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Additional Analysis	Results Reporting limi		Date/Time		Analyst	Method	
Fecal Strentococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C	

In a coloation

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.5 SU	7.2 - 7.8 SU	12/3/24	9:15 AM	JP	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24	9:15 AM	JP	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	9:15 AM	JP	Visual	

Sample comments

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 313

<u>Customer</u>

Facility Name: UPMC Sports Rehab - Cranberry

Address: 8000 Cranberry Springs Drive

Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/3/24

Time: 9:15 AM Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	190/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Additional Analysis	Results Reporting limi		Date/Time		Analyst	Method	
Fecal Strentococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C	

In a coloation

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	7.5 SU	7.2 - 7.8 SU	12/3/24	9:15 AM	JP	DPD	
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/3/24	9:15 AM	JP	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	9:15 AM	JP	Visual	

Sample comments

andre Smith