



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 221

Customer

Facility Name: Masonic Village

Address: 1000 Masonic Dr.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/2/24
Time: 10:51 AM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|-----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 12/3/24 9:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/3/24 9:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/2/24 5:15 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/3/24 9:30 AM | AS | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|------------------|----|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 12/2/24 10:51 AM | AH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 12/2/24 10:51 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/2/24 10:51 AM | AH | Visual |

Sample comments

Anne Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 221

Customer

Facility Name: Masonic Village

Address: 1000 Masonic Dr.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/2/24
Time: 10:51 AM
Method: Grab

Sample Final Analysis

Date: 12/5/24
Time: 9:00 AM
Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|-----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 12/3/24 9:30 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/3/24 9:30 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/2/24 5:15 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 12/3/24 9:30 AM | AS | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|------------------|----|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 12/2/24 10:51 AM | AH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 12/2/24 10:51 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/2/24 10:51 AM | AH | Visual |

Sample comments

Anaë Smith

(When exceeding reporting limit pool or spa is unfit)