



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 314

Customer

Facility Name: UPMC Sports Rehab

Address: 200 Lothrop St.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Therapy Spa

Sample Collection

Date: 12/9/24

Time: 1:45 PM

Method: Grab

Sample Final Analysis

Date: 12/12/24

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	9/10/24 9:10 AM	PS	SM 9222G
-------------------	--------	--------	-----------------	----	----------

Total coliforms:	0/100mls	2/100mls	9/10/24 9:10 AM	PS	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	12/9/24 5:00 PM	AS	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/10/24 9:55 AM	PS	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	12/9/24 1:45 PM	DS	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/9/24 1:45 PM	DS	DPD
-----------	----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	12/9/24 1:45 PM	DS	Visual
------------	-------	-----------	-----------------	----	--------

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 314

Customer

Facility Name: UPMC Sports Rehab

Address: 200 Lothrop St.
Pittsburgh, PA 15213

Matrix: Recreational Water

Source Type: Therapy Spa

Sample Collection

Date: 12/9/24

Time: 1:45 PM

Method: Grab

Sample Final Analysis

Date: 12/12/24

Time: 9:00 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	9/10/24 9:10 AM	PS	SM 9222G
-------------------	--------	--------	-----------------	----	----------

Total coliforms:	0/100mls	2/100mls	9/10/24 9:10 AM	PS	SM 9222B
------------------	----------	----------	-----------------	----	----------

Standard plate count:	0/ml	200/ml	12/9/24 5:00 PM	AS	SM 9215B
-----------------------	------	--------	-----------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/10/24 9:55 AM	PS	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	12/9/24 1:45 PM	DS	DPD
-----	--------	--------------	-----------------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/9/24 1:45 PM	DS	DPD
-----------	----------	----------------	-----------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	12/9/24 1:45 PM	DS	Visual
------------	-------	-----------	-----------------	----	--------

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)