

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Service

Lab ID No. 02-04041

Lab# 312

Customer

Facility Name: **UPMC Lemieux Sports Complex**

Address: 8000 Cranberry Springs Drive

Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge Sample Collection

Date: 2/7/24

Time: 8:10 AM

Method: Grab

Sample Final Analysis

Date: 2/9/24 Time: 1:30 PM

Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 2/7/24 4:15 PM DG SM 9222G Total coliforms: 0/100mls 2/100mls 2/7/24 4:15 PM DG SM 9222B Standard plate count: 0/ml 200/ml 2/7/24 2:59 PM DG SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/7/24	8:10 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/7/24	8:10 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/7/24	8:10 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Service

Lab ID No. 02-04041

Lab# 312

Customer

Facility Name: **UPMC Lemieux Sports Complex**

Address: 8000 Cranberry Springs Drive

Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Cold Plunge Sample Collection

Date: 2/7/24

Time: 8:10 AM

Method: Grab

Sample Final Analysis

Date: 2/9/24 Time: 1:30 PM

Analyst: AS

Laboratory Analysis Results Reporting limit Analyst Method **Incubation Date/Time** Escherichia Coli: Absent Absent 2/7/24 4:15 PM DG SM 9222G Total coliforms: 0/100mls 2/100mls 2/7/24 4:15 PM DG SM 9222B Standard plate count: 0/ml 200/ml 2/7/24 2:59 PM DG SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	2/7/24	8:10 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/7/24	8:10 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/7/24	8:10 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith