1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# **372**

Customer		*Sample Collection*	
Facility Name:	Pine Richland H.S.	*Date:*	*12/5/23*
		Time:	9:30 AM
Address:	700 Warrendale Rd.	*Method:*	*Grab*
	Gibsonia, PA 15044		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	*12/8/23*
		Time:	*9:00 AM*
Source Type:	Deep End	*Analyst:*	AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	9:30 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/5/23	9:30 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	9:30 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# 372

Customer

Facility Name:	Pine Richland H.S.
Address:	700 Warrendale Rd. Gibsonia, PA 15044
Matrix:	Recreational Water
Source Type:	Deep End

Sample Collection

Date:	12/5/23
Time:	9:30 AM
Method:	Grab

Sample Final Analysis

Date:	12/8/23
Time:	9:00 AM
Analyst:	AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	10:45 AM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	10:45 AM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/5/23	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/5/23	9:30 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/5/23	9:30 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/5/23	9:30 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)