1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-3

Lab# *064*

Customer

Facility Name:	*Comfort Inn - RIDC*
Address:	*180 Gamma Dr.*
	Pittsburgh, PA 15238
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*12/3/24*
Time:	10:16 AM
Method:	*Grab*

Sample Final Analysis

Date:	*12/6/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/3/24	10:16 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	12/3/24	10:16 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	10:16 AM	AH	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab#   064

Customer

Facility Name:	*Comfort Inn - RIDC*
Address:	*180 Gamma Dr.*
	Pittsburgh, PA 15238
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*12/3/24*
Time:	10:16 AM
Method:	*Grab*

Sample Final Analysis

Date:	*12/6/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/3/24	10:16 AM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	12/3/24	10:16 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	10:16 AM	AH	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)