

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-2

Lab ID No. 02-04041

Lab# 387

12/6/23

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Residence Inn Cranberry Date:

Address: 1308 Freedom RDd. Time: 12:30 PM Method: Grab

Cranberry, PA 16066

Matrix: Recreational Water Sample Final Analysis

Date: 12/8/23

Source Type: Spa Time: 1:00 PM
Analyst: PS

Laboratory Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 12/6/23 3:22 PM DG SM 9222G Total coliforms: 0/100mls 2/100mls 12/6/23 3:22 PM DG SM 9222B Standard plate count: 0/ml200/ml 12/6/23 2:40 PM DG SM 9215B **Additional Analysis** Results Reporting limit Method Incubation Date/Time **Analyst** 0/100mls SM 9230C Fecal Streptococcus 2/100mls 12/6/23 3:22 PM DG

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/6/23	12:30 PM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	12/6/23	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	12:30 PM	VH	Visual

Sample comments

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

N-2

Lab ID No. 02-04041

Lab# 387

12/6/23

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Residence Inn Cranberry Date:

Address: 1308 Freedom RDd. Time: 12:30 PM Method: Grab

Cranberry, PA 16066

Matrix: Recreational Water Sample Final Analysis

Date: 12/8/23

Source Type: Spa Time: 1:00 PM
Analyst: PS

Laboratory Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 12/6/23 3:22 PM DG SM 9222G Total coliforms: 0/100mls 2/100mls 12/6/23 3:22 PM DG SM 9222B Standard plate count: 0/ml200/ml 12/6/23 2:40 PM DG SM 9215B **Additional Analysis** Results Reporting limit Method Incubation Date/Time **Analyst** 0/100mls SM 9230C Fecal Streptococcus 2/100mls 12/6/23 3:22 PM DG

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/6/23	12:30 PM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	12/6/23	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	12:30 PM	VH	Visual

Sample comments

andre Smith