

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-2

Lab ID No. 02-04041

Lab# 247

Customer Sample Collection

Facility Name: Oxford Athletic Club Date: 12/4/24 Time: 9:45 AM Address: 100 Village Club Dr. Method: Grab

Wexford, PA 15090

Sample Final Analysis Matrix: Recreational Water Date: 12/7/24

Time: 12:00 AM Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	8.0 SU	7.2 - 7.8 SU	12/4/24	9:45 AM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	9:45 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	9:45 AM	VH	Visual	

Sample comments

Andre Smith, Lead Supervisor

Indee Smith

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-2

Lab ID No. 02-04041

Lab# 247

Customer Sample Collection

Facility Name: Oxford Athletic Club Date: 12/4/24 Time: 9:45 AM Address: 100 Village Club Dr. Method: Grab

Wexford, PA 15090

Sample Final Analysis Matrix: Recreational Water Date: 12/7/24

Time: 12:00 AM Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	6:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	8.0 SU	7.2 - 7.8 SU	12/4/24	9:45 AM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	9:45 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	9:45 AM	VH	Visual	

Sample comments

Andre Smith, Lead Supervisor

Indee Smith

(When exceeding reporting limit pool or spa is unfit)