**1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

P.P.S.

Lab# 253

Customer

Facility Name: Perry Traditional Academy

Address: 3875 Perrysville Ave.
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 12/3/24
Time: 1:55 PM
Method: Grab

Sample Final Analysis

Date: 12/6/24
Time: 9:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/3/24	1:55 PM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	B	12/3/24	1:55 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/3/24	1:55 PM	JM	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab#   253

Customer

Facility Name:	*Perry Traditional Academy*
Address:	*3875 Perrysville Ave.*
	Pittsburgh, PA 15214
Matrix:	*Recreational Water*
Source Type:	*Pool Shallow*

Sample Collection

Date:	*12/3/24*
Time:	1:55 PM
Method:	*Grab*

Sample Final Analysis

Date:	*12/6/24*
Time:	*9:00 AM*
Analyst:	*AS*

Laboratory Analysis	Results	Reporting limit	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/3/24	1:55 PM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	B	12/3/24	1:55 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/3/24	1:55 PM	JM	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)