



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041  
W-1

Lab# 008

**Customer**

Facility Name: Allegheny Valley School Ingram  
Address: 315 W. Prospect Ave.  
Pittsburgh, PA 15205

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 12/2/24  
Time: 7:25 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/5/24  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24 9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24 9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24 5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24 7:25 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24 7:25 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24 7:25 AM	AH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041  
W-1

Lab# 008

**Customer**

Facility Name: Allegheny Valley School Ingram  
Address: 315 W. Prospect Ave.  
Pittsburgh, PA 15205

Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 12/2/24  
Time: 7:25 AM  
Method: Grab

**Sample Final Analysis**

Date: 12/5/24  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24 9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24 9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24 5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/2/24 7:25 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24 7:25 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24 7:25 AM	AH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)