



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 302

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.
Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Lg Pool Deep

Sample Collection

Date: 12/3/24

Time: 3:00 PM

Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM

Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/4/24 | 11:00 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/4/24 | 11:00 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/3/24 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 12/3/24 | 3:00 PM | SCL | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/3/24 | 3:00 PM | SCL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/3/24 | 3:00 PM | SCL | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 302

Customer

Facility Name: University of Pittsburgh

Address: 3501 Allequippa St.
Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Lg Pool Deep

Sample Collection

Date: 12/3/24

Time: 3:00 PM

Method: Grab

Sample Final Analysis

Date: 12/6/24

Time: 9:00 AM

Analyst: AS

| Laboratory Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/4/24 | 11:00 AM | PS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/4/24 | 11:00 AM | PS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/3/24 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 12/3/24 | 3:00 PM | SCL | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 12/3/24 | 3:00 PM | SCL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/3/24 | 3:00 PM | SCL | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)