

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-2

Lab ID No. 02-04041

Lab# 168

Customer Sample Collection

Facility Name: Home 2 Suites Date: Time: Address: 8630 Duncan Ave.

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

12/4/24 8:30 AM Method: Grab

Sample Final Analysis

12/7/24 Date: Time: 9:00 AM AS Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G	
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B	
Standard plate count:	0/ml	200/ml	12/4/24	4:15 PM	AS	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	8:30 AM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	8:30 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	8:30 AM	VH	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-2

Lab ID No. 02-04041

Lab# 168

Customer Sample Collection

Facility Name: Home 2 Suites Date: Time: Address: 8630 Duncan Ave.

Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

12/4/24 8:30 AM Method: Grab

Sample Final Analysis

12/7/24 Date: Time: 9:00 AM AS Analyst:

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method	
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G	
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B	
Standard plate count:	0/ml	200/ml	12/4/24	4:15 PM	AS	SM 9215B	

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	12/4/24	8:30 AM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	8:30 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	8:30 AM	VH	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith