

## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3** 

Lab# 172

Sample Collection **Customer** 

Facility Name: Homewood Suites Date: 12/2/24

Time: 9:15 AM Address: 3000 Horizon Vue Dr. Method: Grab

Cannonsburg, PA 15317

Sample Final Analysis Date: Matrix: Recreational Water 12/5/24

Time: 9:00 AM Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	12/2/24	9:15 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:15 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:15 AM	JM	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)



## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3** 

Lab# 172

Sample Collection **Customer** 

Facility Name: Homewood Suites Date: 12/2/24

Time: 9:15 AM Address: 3000 Horizon Vue Dr. Method: Grab

Cannonsburg, PA 15317

Sample Final Analysis Date: Matrix: Recreational Water 12/5/24

Time: 9:00 AM Source Type: Spa Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	12/2/24	9:15 AM	JM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/2/24	9:15 AM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	9:15 AM	JM	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)