



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 244

**Customer**

Facility Name: Oliver H.S.  
Address: 2323 Brighton Rd.  
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/3/24  
Time: 1:35 PM  
Method: Grab

**Sample Final Analysis**

Date: 12/6/24  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/3/24	1:35 PM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	B	12/3/24	1:35 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/3/24	1:35 PM	JM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)



1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report

Lab ID No. 02-04041

P.P.S.

Lab# 244

**Customer**

Facility Name: Oliver H.S.  
Address: 2323 Brighton Rd.  
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 12/3/24  
Time: 1:35 PM  
Method: Grab

**Sample Final Analysis**

Date: 12/6/24  
Time: 9:00 AM  
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	A	12/4/24	10:15 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	A	12/4/24	10:15 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	A	12/3/24	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Rating		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	A	12/3/24	1:35 PM	JM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	B	12/3/24	1:35 PM	JM	DPD
Turbidity:	1 NTU	1 - 2 NTU	A	12/3/24	1:35 PM	JM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)