1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab#   173

Customer
Facility Name: *Hopewell High School*

Address: *1215 Longvue Ave.*
Aliquippa, PA 15001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection
Date: *12/2/24*
Time: 12:17 PM
Method: *Grab*

Sample Final Analysis
Date: *12/5/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/2/24	12:17 PM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	12/2/24	12:17 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	12:17 PM	AH	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# **173**

Customer

Facility Name:	Hopewell High School
Address:	1215 Longvue Ave.
	Aliquippa, PA 15001
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	12/2/24
Time:	12:17 PM
Method:	Grab

Sample Final Analysis

Date:	12/5/24
Time:	9:00 AM
Analyst:	AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/24	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/24	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/2/24	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/2/24	12:17 PM	AH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	12/2/24	12:17 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/2/24	12:17 PM	AH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)