

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-2

Lab# 210

Customer Sample Collection

Facility Name: L.A. Fitness North Hills Date: 12/4/24 Time: 8:15 AM

8700 Duncan Ave. Address: Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Method: Grab

Sample Final Analysis

12/7/24 Date: Time: 9:00 AM Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	8.0 SU	7.2 - 7.8 SU	12/4/24	8:15 AM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	8:15 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	8:15 AM	VH	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

anobie Smith



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-2

Lab# 210

Customer Sample Collection

Facility Name: L.A. Fitness North Hills Date: 12/4/24 Time: 8:15 AM

8700 Duncan Ave. Address: Pittsburgh, PA 15237

Matrix: Recreational Water

Source Type: Pool

Method: Grab

Sample Final Analysis

12/7/24 Date: Time: 9:00 AM Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/5/24	9:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/5/24	9:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/4/24	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	
рН:	8.0 SU	7.2 - 7.8 SU	12/4/24	8:15 AM	VH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/4/24	8:15 AM	VH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	12/4/24	8:15 AM	VH	Visual	

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

anobie Smith