1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
E-2

Lab# 002

Customer

Facility Name: *Aerobics Center*

Address: *526 New Alexandria Rd.*
Greensburg, PA 15601

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *12/3/24*
Time: 12:29 PM
Method: *Grab*

Sample Final Analysis

Date: *12/6/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/3/24	12:29 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:29 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:29 PM	JC	Visual

Sample comments

Andrea Smith, Lead Supervisor

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
E-2

Lab# 002

Customer

Facility Name: *Aerobics Center*

Address: *526 New Alexandria Rd.*
Greensburg, PA 15601

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *12/3/24*
Time: 12:29 PM
Method: *Grab*

Sample Final Analysis

Date: *12/6/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/4/24	9:30 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/4/24	9:30 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/24	3:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/4/24	9:00 AM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	12/3/24	12:29 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/3/24	12:29 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/24	12:29 PM	JC	Visual

Sample comments

Andrea Smith, Lead Supervisor

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)