1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 425

Customer

Facility Name: *Chatham University*

Address: *1 Woodland Rd.*
Pittsburgh, PA 15232

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *12/16/24*
Time: 11:35 AM
Method: *Grab*

Sample Final Analysis

Date: *12/19/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/17/24	10:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/17/24	10:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/16/24	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/16/24	11:35 AM	MB	DPD
Chlorine:	2.4 mg/l	1.0 - 5.0 mg/l	12/16/24	11:35 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/16/24	11:35 AM	MB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 425

Customer

Facility Name: *Chatham University*

Address: *1 Woodland Rd.*
Pittsburgh, PA 15232

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *12/16/24*
Time: 11:35 AM
Method: *Grab*

Sample Final Analysis

Date: *12/19/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/17/24	10:00 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/17/24	10:00 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	12/16/24	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	12/16/24	11:35 AM	MB	DPD
Chlorine:	2.4 mg/l	1.0 - 5.0 mg/l	12/16/24	11:35 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/16/24	11:35 AM	MB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith