1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 432

Customer

Facility Name: *Chatham University*

Address: *1 Woodland Rd.*
Pittsburgh, PA 15232

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *2/5/24*
Time: 9:55 AM
Method: *Grab*

Sample Final Analysis

Date: *2/8/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/6/24	9:50 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/6/24	9:50 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	2/5/24	4:49 PM	DG	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/5/24	9:55 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/5/24	9:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/5/24	9:55 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 432

Customer

Facility Name: *Chatham University*

Address: *1 Woodland Rd.*
Pittsburgh, PA 15232

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *2/5/24*
Time: 9:55 AM
Method: *Grab*

Sample Final Analysis

Date: *2/8/24*
Time: *9:00 AM*
Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/6/24	9:50 AM	PS	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/6/24	9:50 AM	PS	SM 9222B
Standard plate count:	0/ml	200/ml	2/5/24	4:49 PM	DG	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00	12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/5/24	9:55 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	2/5/24	9:55 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/5/24	9:55 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)