1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-2

Lab# 452

Customer

Facility Name: *Doubletree Cranberry*

Address: *910 Sheraton Dr*
Mars, PA 16046

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/6/23*
Time: 11:30 AM
Method: *Grab*

Sample Final Analysis

Date: *12/8/23*
Time: *1:00 PM*
Analyst: *PS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/6/23	11:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	11:30 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-2

Lab# 452

Customer

Facility Name: *Doubletree Cranberry*

Address: *910 Sheraton Dr*
Mars, PA 16046

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/6/23*
Time: 11:30 AM
Method: *Grab*

Sample Final Analysis

Date: *12/8/23*
Time: *1:00 PM*
Analyst: *PS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/6/23	3:22 PM	DG	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/6/23	3:22 PM	DG	SM 9222B
Standard plate count:	0/ml	200/ml	12/6/23	2:40 PM	DG	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	12/6/23	11:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/6/23	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/6/23	11:30 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith